

**From:** [David Webb](#)  
**To:** [Billy Dentmon](#); [Rick Baldwin](#); [Tammy Burton](#)  
**Cc:** [Andy Chisholm](#); [Lynn Bateman](#)  
**Subject:** RE: Rooms To Go-Seffner Pre-bid RFI#8-Cabinetry & Millworks  
**Date:** Tuesday, September 21, 2021 4:35:02 PM  
**Attachments:** [image001.png](#)

**CAUTION: This email originated from outside the organization. Use caution with links and attachments.**

See response to Request for Information below in **Red**.

**David H. Webb, AIA**  
*Associate*

O: 727.725.8880 | C: 813.951.5883  
[www.fleischmangarcia.com](http://www.fleischmangarcia.com)  
Tampa | Safety Harbor | Sarasota



---

**From:** Billy Dentmon <billy\_dentmon@wedentmonconst.com>  
**Sent:** Monday, September 20, 2021 1:53 PM  
**To:** David Webb <David@fgafla.com>  
**Cc:** Andy Chisholm <andy\_chisholm@wedentmonconst.com>; Lynn Bateman <lynn\_bateman@wedentmonconst.com>  
**Subject:** Rooms To Go-Seffner Pre-bid RFI#8-Cabinetry & Millworks

David,

Please respond ASAP to the following questions:

A. **Cabinets:** (Follow Drawings and Specifications)

- 1- Box material - 3/4" plywood laminated or 3/4" Melamine / Doors?
- 2- Interior of Boxes Laminated with either material?
- 3- Drawer Material - 1/2" plywood laminated both sides or 1/2" melamine?
- 4- Drawers Laminated with either material?

B. **Hardware:**

- 1- Stanley #SP41 - showed as discontinued when searched. (Stanley #CD46 is acceptable)
- 2- Pulls specified is Mocket DP281A but spec on detail for drawers and door pulls spec SWP-640/5?

C. **Laminate Walls:**

- 1- Material for outside trim is not really the applicable application -Inpro trim #407A. (We have used this trim successfully on previous projects)
- 2- I am assuming this material would be for the ends as well or would the edge be laminated? (All exposed edges of the laminate panels are to receive this trim)

- D. The below areas look to have cabinets / millwork but no elevations are indicated? Please

advise.

B170-Office (By Owner)

B161-Breakroom (Existing to remain)

B159-OCC Health (By Owner)

Thank You,

Billy Dentmon, President

W. E. Dentmon Construction, Inc.

2500 Drane Field Rd., Suite 201

Lakeland, FL 33811

O= 813.620.0888

F= 813.628.4262

C= 813.918.9836

E= [billy@wedentmonconst.com](mailto:billy@wedentmonconst.com)

***“A Reputation You Can Build On”***