


- ◆ CONNECT NEW RELOCATED EQUIPMENT TO EXISTING RECEPTACLE.
- ◆ EXISTING POWER POLES TO REMAIN.
- ◆ EXISTING CIRCUIT RELOCATED. PROVIDE ALL REQUIRED CORDS, CABLES, ETC. TO NEW RELOCATION.
- ◆ CONTRACTOR TO INSTALL NEW POWER POLE. INSTALL NEW CABLES AT TOP OF POWER POLE LOCATED ABOVE CEILING. COORDINATE WITH PUBLIC REPRESENTATIVE FOR CORDS TO BE RELOCATED.
- ◆ CONNECT NEW CHECKSTAND TO EXISTING/RELOCATED CIRCUIT/RECEPTACLE. CONTRACTOR TO INSTALL WALKER BEETLE, AS REQUIRED FOR NEW CHECKSTAND INSTALLATION.
- ◆ MOVE RECEPTACLE TO BACK OF REFRIGERATED CASE. SEE RELOCATION FOR DETAILS.
- ◆ CONNECT EQUIPMENT TO EXISTING RECEPTABLES AFTER MILLWORK IS COMPLETE.
- ◆ CONTRACTOR TO INSTALL NEW POWER POLE AND LOCATED NEW CABLES AND CIRCUITS TO NEW POWER POLE. INSTALL JUNCTION BOX AT TOP OF POWER POLE LOCATED ABOVE CEILING. COORDINATE WITH PUBLIC REPRESENTATIVE FOR LOCATION PRIOR TO ROUGH-IN.
- ◆ CONTRACTOR TO RELOCATE EXISTING CORD REEL AND CORDS TO EXISTING RECEPTACLE.
- ◆ NEW HOOD CONTROL PANEL. SEE WIRING DIAGRAM Q22.
- ◆ CONTRACTOR TO CONNECT NEW CORDING TO EXISTING POWER AND CONTROL CIRCUITS.
- ◆ CONTRACTOR TO CONNECT NEW WATER HEATER TO EXISTING WATER SUPPLY AND DRAIN.

- A. ALL INSTALLED CIRCUITS REQUIRE AN EQUIPMENT GROUND CONDUCTOR REGARDLESS OF WIRE COUNT SHOWN ON DRAWING.
- B. ISOLATED GROUND CIRCUITS ARE TO BE IN ADDITION TO EQUIPMENT GROUND CONDUCTOR AND SHALL BE CONNECTED TO AN ISOLATED GROUND BUS IN ITS RESPECTIVE PANEL.
- C. DELIVERABLES/POWER POLE LOCATIONS MAY CHANGE DUE TO UP-CHARGE CHANGES. THE CONTRACTOR SHALL BE RESPONSIBLE TO VERIFY EACH ELECTRICAL POWER POLE LOCATIONS WITH PUBLIC REPRESENTATIVE PRIOR TO ROUTE-IN.
- D. APPLICABLE CONTRACTORS' INSTALLATION TO MEET ALL APPLICABLE CODES AND THE VERSION OF THE NATIONAL ELECTRICAL CODE, ASADOPTED BY THE JURISDICTION HAVING AUTHORITY.
- E. CONTRACTOR TO PROVIDE BREWER HANDLE TIES FOR ALL CIRCUITS TO BE SHARED NEUTRAL TO COMPLY WITH NFPA SECTION 250.4.1.
- F. SHUNT TRIP AND LOCKOUT SWITCHES TO BE MOUNTED AT 66" AFF. COORDINATE EXACT LOCATION AND REQUIREMENTS WITH THE JURISDICTION PROVIDING STAGE STANDING/EQUIPMENT SHUTOFF.
- G. ALL CONDUCITS INSTALLED IN AREAS VISIBLE TO THE PUBLIC SHALL BE COVERED BY A FLOOR FINISH OR FLOORING WHEN OTHER WORK IS BEING DONE TO REQUIRE THE FLOOR TO BE SAW CUT, OR ROUTED ALONG THE BOTTOM OF THE WALL. ALL PREVIOUSLY INSTALLED 1" AFF. 50 CONDUCITS ARE NOT VISIBLE AT ANY POINT TO THE



DELI HOOD #2 CONTROL PANE

1 ELECTRICAL
E2.1 SCALE: 1/8"=1'-0"

0 2' 4' 8' 16'

SCALE: 1/8" = 1'-0"

NOTE: THIS DOCUMENT MAY HAVE BEEN ELECTRONICALLY TRANSMITTED. IF UNSIGNED IT CANNOT BE FILED FOR PUBLIC RECORD. PUBLIC RECORD FILINGS REQUIRE SIGNED AND SEALED DOCUMENTS.

DECOR SCHEME: EVERGREEN