

ELECTRICAL POWER DEMOLITION PLAN

ED2.1 SCALE: 1/8"=1'-0"

0 2' 4' 8' 16'

SCALE: 1/8" = 1'-0"

LEGEND

ITEMS TO BE DEMOLISHED.

KEYED NOTES

1. DISCONNECT REFRIGERATED CASE FOR REMOVAL. EXTEND/REWORK EXISTING CIRCUITS AND MODIFY RACEWAY AS REQUIRED TO CONNECT NEW CASE(S) TO EXISTING CIRCUITS. REFER TO DWG. E3.1 FOR ADDITIONAL INFORMATION.
2. DISCONNECT EQUIPMENT FOR RELOCATION. RELOCATE EXISTING CIRCUIT AND MODIFY CONDUIT AS REQUIRED. REFER TO DWG. E2.1 FOR ADDITIONAL INFORMATION.
3. DISCONNECT EQUIPMENT FOR REMOVAL. EXISTING CIRCUIT TO BE REMOVED BACK TO SOURCE.
4. DISCONNECT EQUIPMENT FOR RELOCATION. EXISTING RECEPTACLE TO REMAIN FOR FUTURE USE.
5. DISCONNECT REFRIGERATED CASE FOR REMOVAL. EXISTING LITE LAB POWER DOWN TO BE REMOVED.
6. DISCONNECT EQUIPMENT FOR REMOVAL, EXISTING CORD REEL AND CIRCUIT TO BE RELOCATED TO NEW EQUIPMENT LOCATION.
7. DISCONNECT REFRIGERATED CASE FOR RELOCATION EXISTING CIRCUIT TO BE RETAINED/REWORKED FOR INSTALLATION OF NEW REFRIGERATED CASE.
8. DISCONNECT RECEPTACLES AND DATA OUTLETS FROM DEMOLISHED WALL. EXISTING CIRCUITS ARE TO BE REMOVED BACK TO SOURCE.
9. DISCONNECT EQUIPMENT FOR REMOVAL. EXISTING RECEPTACLE TO REMAIN FOR FUTURE USE.
10. DISCONNECT CHECKSTAND FOR REMOVAL. EXISTING CIRCUITS ARE TO BE RELOCATED FOR INSTALLATION OF NEW CHECKSTANDS.
11. DISCONNECT EQUIPMENT AS REQUIRED FOR NEW MILLWORK, EXISTING RECEPTACLES TO REMAIN.
12. EXISTING POWER POLE TO BE REPLACED. REFER TO DWG. E2.1 FOR NEW POWER POLE LOCATION.
13. DISCONNECT EQUIPMENT FOR REMOVAL. EXISTING CIRCUITS ARE TO BE RELOCATED TO NEW EQUIPMENT LOCATION.
14. DISCONNECT GREASE HOOD FOR MECHANICAL CONTRACTOR'S REMOVAL. EXISTING CONTROLS TO BE REMOVED BACK TO SOURCE.
15. EXISTING POWER POLE TO BE REPLACED. CONTRACTOR TO RELOCATE EXISTING RECEPTACLES AND CIRCUITS TO NEW POWER POLE.
16. CONTRACTOR TO REMOVE ALL ELECTRICAL DEVICES FROM WALL. EXISTING CIRCUITS TO BE REMOVED BACK TO SOURCE.
17. CONTRACTOR TO DISCONNECT FREEZER/COOLER FOR REMOVAL. EXISTING CIRCUITS ARE TO BE RETAINED FOR INSTALLATION OF NEW FREEZER/COOLER.
18. CONTRACTOR TO DISCONNECT COMPACTOR FOR REMOVAL. EXISTING CIRCUITS ARE TO BE RETAINED FOR INSTALLATION OF NEW COMPACTOR.
19. CONTRACTOR TO DISCONNECT WATER HEATER FOR PLUMBING CONTRACTORS REMOVAL. EXISTING CIRCUITS ARE TO BE RETAINED FOR INSTALLATION OF NEW WATER HEATER.

GENERAL NOTES

1. CONTRACTOR SHALL MAKE PRELIMINARY SITE VISIT AND VERIFY THE MAGNITUDE AND SCOPE OF THE PROJECT BEFORE BIDDING.
2. CONTRACTOR SHALL DISCONNECT AND REMOVE ALL ELECTRICAL EQUIPMENT, DEVICES, PANELBOARDS, AND LIGHTING FIXTURES AS INDICATED.
3. MANY EXISTING CIRCUIT/HOMERUNS SHALL BE REROUTED TO BREAKERS AND/OR PANELS. CONTRACTOR SHALL VERIFY CIRCUITING. CONTRACTOR TO VERIFY THE EXTENT OF SCOPE FOR THIS WORK WITH PUBLIX REPRESENTATIVE AND A CHANGE ORDER WILL BE ISSUED AS REQUIRED FOR THIS WORK.
4. ALL EQUIPMENT REMOVED SHALL NOT BE REUSED WITHOUT WRITTEN APPROVAL FROM PUBLIX REPRESENTATIVE.
5. ALL EQUIPMENT REMOVED SHALL BE TURNED OVER TO PUBLIX REPRESENTATIVE AND SHALL REMAIN PROPERTY OF THE OWNER.
6. CONTRACTOR SHALL VERIFY LAMP BALLAST TYPE FOR EXISTING TO REMAIN LIGHT FIXTURES. T-12 LAMPS AND BALLAST SHALL BE REPLACED WITH NEW T-8 LAMPS AND ELECTRONIC BALLAST AS REQUIRED THROUGHOUT THE STORE AND ROOF. CONTRACTOR TO VERIFY THE EXTENT OF SCOPE FOR THIS WORK WITH PUBLIX REPRESENTATIVE AND A CHANGED ORDER WILL BE ISSUED AS REQUIRED FOR THIS WORK.
7. IT IS THE RESPONSIBILITY OF THE ELECTRICAL CONTRACTOR TO IDENTIFY AND VERIFY ALL CIRCUITS ON SITE AND TO MAKE CHANGES ACCORDING TO THE ARCHITECTURAL DEMOLITION SCOPE OF WORK.

NOTE: THIS DOCUMENT MAY HAVE BEEN ELECTRONICALLY TRANSMITTED. IF UNSIGNED, IT CANNOT BE FILED FOR PUBLIC RECORD. PUBLIC RECORD FILINGS REQUIRE SIGNED AND SEALED DOCUMENTS.

CUHACI PETERSON
2600 Maitland Center Parkway
Suite #200
Maitland, FL 32751
P (407) 661-9100
F (407) 661-9101
c-p.com
Florida Corporate Certificate #AA C000526

BRANDT ENGINEERING, INC.
2845 POLO PARKWAY, SUITE 205
MIDLOTHIAN, VA 23113
PHONE: (804)794-6656
FAX: (804)794-8588
EMAIL: cods@beinc.com
FL Firm Registration # 26689

R. KNOX STACY - ELECTRICAL
LICENSE #63643,
EXPIRATION DATE: 2/28/2023

Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

R. KNOX STACY LICENSE No 63643 STATE OF FLORIDA PROFESSIONAL ENGINEER

This item has been digitally signed and sealed by Robert K Stacy on the date adjacent to the seal.

2022.10.12 11:22:15-04'00'

CLIENT NAME: Publix. SUPER MARKETS
3300 PUBLIX CORPORATE PARKWAY
LAKELAND, FL 33811-3311

PROJECT NAME: PUBLIX AT CRYSTAL SPRINGS SHOPPING CENTER #0797
6700 BLUE LAKE HIGHWAY
CRYSTAL RIVER, FLORIDA 34429-9348

SHEET TITLE: ELECTRICAL POWER DEMOLITION PLAN

REV	RELEASE
1	100% SUBMITTAL - 21 APR 2022
2	RR80965 - BLAST CHILLER - 12 OCT 2022

PROJECT NO.	DATE	DRAWN	CHECKED
2210764	04/21/2022	BS	RKS

ED2.1

DECOR SCHEME: EVERGREEN

ALL IDEAS, DESIGNS, CONCEPTIONS & ARRANGEMENTS SHOWN, INDICATED & REPRESENTED ON THESE DRAWINGS & ALL COPYRIGHTS, RIGHTS TO REPRODUCTION OF AND COMMON LAW RIGHTS THEREIN ARE & SHALL REMAIN THE EXCLUSIVE PROPERTY OF CUHACI PETERSON ARCHITECTS, INC. & SHALL NOT BE USED BY OR DISCLOSED TO ANY PERSON, FIRM OR CORPORATION FOR ANY PURPOSE WHATSOEVER WITHOUT THE WRITTEN PERMISSION OF CUHACI PETERSON ARCHITECTS, INC.

10/11/2022 5:06:14 PM