



1 HVAC DEMOLITION PLAN  
MD1.1  
SCALE: 1/8"=1'-0"

LEGEND

- INDICATES EXISTING WORK TO BE REMOVED
- INDICATES EXTENT OF DEMOLITION WORK

DEMOLITION NOTES:

- REFRIGERATED CASE TO BE REMOVED. DISCONNECT RETURN AIR DROP FROM CASE. DUCT SHALL RECONNECT TO NEW CASE. SEE RENOVATION PLAN M1.
- ROOF TOP UNIT TO BE REMOVED. ROOF CURB AND DUCT SYSTEM SHALL REMAIN TO BE REUSED. CONTRACTOR SHALL BE RESPONSIBLE FOR RECLAMATION AND DISPOSAL OF ALL REFRIGERANT PER LOCAL AND NATIONAL LAWS/CODES. SEE RENOVATION PLAN M1 FOR NEW WORK.
- SMOKE DETECTORS TO BE REMOVED AND REPLACED. SEE RENOVATION PLAN M1.
- REFRIGERATION CONTRACTOR SHALL BE RESPONSIBLE FOR DISCONNECTING EXISTING HEAT RECLAIM CIRCUITS.
- TEMPERATURE SENSOR TO BE REMOVED AND REPLACED. SEE RENOVATION PLAN M1.
- HANDY SENSOR TO BE REMOVED AND REPLACED. SEE RENOVATION PLAN M1.
- ROOF MOUNTED EXHAUST FAN IS TO BE REMOVED FROM ROOF. REMOVE FAN, DUCTWORK, AND ALL ASSOCIATED APPURTENANCES. CURB SHALL REMAIN TO BE CAPPED AND SEALED. SEE RENOVATION PLAN M1.
- GREASE HOOD GH-1 IS TO BE REMOVED. REMOVE HOOD, ANSUL PULL STATION, ANSUL PING, AND ALL ASSOCIATED APPURTENANCES. COORDINATE WITH OTHER DISCIPLINES AS REQUIRED FOR REMOVAL.
- ROOF MOUNTED EXHAUST FAN TO BE REMOVED. CURB, DUCTWORK AND ALL ASSOCIATED APPURTENANCES SHALL BE REMOVED. ROOF PENETRATION SHALL BE MODIFIED AS REQUIRED TO BE REUSED. SEE RENOVATION PLAN M1.
- AIR DEVICES AND CONNECTING DUCTWORK SHOWN HATCHED TO BE REMOVED. SEE RENOVATION PLAN M1 FOR NEW WORK.
- EXISTING ERV-1 TO BE REMOVED FROM ROOF. REMOVE UNIT, DUCTWORK SHOWN HATCHED. CURB AND ALL ASSOCIATED APPURTENANCES. EXISTING EXHAUST RISER SHALL BE REMOVED BACK TO 3'-0" BELOW ROOF DECK. EXISTING ROOF PENETRATION SHALL BE REUSED. SEE RENOVATION PLAN M1 FOR NEW WORK.

NOTE: THIS DOCUMENT MAY HAVE BEEN ELECTRONICALLY TRANSMITTED. IF UNSIGNED, IT CANNOT BE FILED FOR PUBLIC RECORD. PUBLIC RECORD FILINGS REQUIRE SIGNED AND SEALED DOCUMENTS.

MD1.1  
DECOR SCHEME: EVERGREEN

PROJECT NO.	220204
DATE	07/11/2022
DRAWN	JAN 11/24
CHECKED	JAN 11/24

PUBLIX AT CRYSTAL SPRINGS SHOPPING CENTER #0797  
CRYSTAL SPRINGS SHOPPING CENTER  
CRYSTAL RIVER, FLORIDA 34429-6348

PROJECT NAME  
PUBLIX AT CRYSTAL SPRINGS SHOPPING CENTER #0797  
CRYSTAL SPRINGS SHOPPING CENTER  
CRYSTAL RIVER, FLORIDA 34429-6348

CLIENT NAME  
PUBLIX  
3300 PULASKI CORPORATE PARKWAY  
LAKELAND, FL 33811-3311

BRANDT ENGINEERING, INC.  
340 P.O. BOX 200  
MILWAUKEE, WI 53103  
PHONE: (800) 794-8888  
FAX: (800) 794-8888  
EMAIL: cedd@beinc.com  
FL Firm Registration # 26689  
JOHN S. PARKER - MECHANICAL  
LICENSE #63481  
EXPIRATION DATE: 2/28/2023

CUHACI PETERSON  
2600 Mallard Center Parkway  
Suite #200  
Mallard, FL 32751  
P (407) 661-9100  
F (407) 661-9101  
c-p.com  
Florida Corporate Certificate #AA C200201