

Store #0797: Publix at Crystal Springs Shopping Center, 6760W Gulf to Lake Highway, Crystal River FL 34429-9348

C&P Project Number: #2210764

Print Date: 10/26/2022

***Delta 1 – Blast Chiller RR#30985
Dated: 10/12/2022***

Delta 1 – RR#30985:

Remove Unified BC-18 Blast Chiller in Deli, replace it with Desmon GBF-15 Middleby Blast Chiller in Deli.

Revised Sheets :

ARCHITECTURAL:

D1.1 – DEMOLITION PLAN

- Updated Blast Chiller to demolition.

EQ.1 – EQUIPMENT PLAN

- Updated Blast Chiller model.

A5.1 – ROOF PLAN

- Added new Exhaust Fan F-2.

STRUCTURAL:

S4.1 – ROOF FRAMING PLAN

- Updated framing for new Exhaust Fan F-2.

MECHANICAL:

MD1.1 – HVAC DEMOLITION PLAN

- Removed ERV-1 and associated ductwork.
- Added Key Note 12.

M1.1 – HVAC RENOVATION PLAN

- Added new Exhaust Fan F-2.

M3.1 – HVAC SCHEDULES

- Updated Existing Fan & Fan Curb Schedules.

M4.1 – HVAC HOOD SECTIONS, SCHEDULES AND DETAILS

- Updated New Fan Schedule.
- Updated New Curb Schedule.

ELECTRICAL:**ED2.1 – ELECTRICAL POWER DEMOLITION PLAN**

- Remove Blast Chiller and circuit.

ED2.2 – ELECTRICAL ROOF POWER DEMOLITION PLAN

- Added Key Note 6.

E2.1 – ELECTRICAL POWER PLAN

- Added circuit for Blast Chiller.

E2.2 – ELECTRICAL ROOF POWER PLAN

- Added circuit for new Exhaust Fan F-2.

E11.1 – ELECTRICAL PANEL SCHEDULES

- Updated Panel K, M, & R.

REFRIGERATION:**R1.0 – REFRIGERATION DEMOLITION PLAN**

- Updated Blast Chiller notes.

R1.1 – REFRIGERATION FLOOR PLAN

- Updated New Blast Chiller.

End of changes for RR#30985